

LISTING SERVICE

LISTING No.:	8160-2180:0501
CATEGORY:	8160 - UNDER EAVE FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	Plycem USA 396 W. Greens Rd., Suite 300, Houston, TX, 77067 Contact: Herrington, Shawn 844-425-5872 Email: sherrington@elementia.com
DESIGN:	Allura un-vented, fiber-cement soffit, 1/4" thick, under eave material. Refer to the manufacturer's installation instructions and product data sheets.
RATING:	Tested in accordance with ASTM E84 with an additional 20 minutes.
	Class A
	Flame Spread Index: 0
	Smoke Developed Index: 5
	Max Flame Front: 0 feet
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, rating, and SFM label.
APPROVAL:	Listed as under eave material for use in the Wildland Urban Interface areas. Refer to listee's Installation Instruction Manual for details. Model complies with the applicable requirements in SFM 12-7A-5.
NOTES:	Test Protocol SFM 12-7A-5

8-11-22 VWW





LISTING SERVICE

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an

endorsement or recommendation o requirements or installation criteria. information sources.	endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.		fy correct operational d/or other suitable
Date Issued: 06/22/2023			Listing Expires: 06/30/2024
Authorized By: Victor Wong , Program Coordinate Fire Engineering & Investigations D	or Division		



LISTING SERVICE

LISTING No.:	8140-2180:0001
CATEGORY:	8140 - EXTERIOR WALL SIDING AND SHEATHING FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	Plycem USA 396 W. Greens Rd., Suite 300, Houston, TX, 77067 Contact: Herrington, Shawn 844-425-5872 Email: sherrington@elementia.com
DESIGN:	"Weatherboards™" lap siding, fiber-cement, type "Smooth, Cedar, Smooth Bead, Textured Bead, Select Cedar, Dutch Lap", 5/16" thick, 5 ¼" to 12" width, 12' length. Refer to the manufacturer's installation instructions and product data sheets.
RATING:	Compliance in accordance with Chapter 7A of the California Building Code.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee name. Model number, rating and SFM label.
APPROVAL:	Listed as exterior siding for use in the Wildland Urban Interface areas.
NOTES:	Listing formerly: 8140-2024:0001

11/4/14-dg



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/22/2023 Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator Fire Engineering & Investigations Division



LISTING SERVICE

LISTING No.:	8140-2180:0002
CATEGORY:	8140 - EXTERIOR WALL SIDING AND SHEATHING FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	Plycem USA 396 W. Greens Rd., Suite 300, Houston, TX, 77067 Contact: Herrington, Shawn 844-425-5872 Email: sherrington@elementia.com
DESIGN:	"Weatherboards™" shapes siding, fiber-cement, type "Perfection Shingle, Random Square Staggered Edge, Half Rounds, Octagons, 5/16" thick, 16" width, 48" length. Refer to the manufacturer's installation instructions and product data sheets.
RATING:	Compliance in accordance with Chapter 7A of the California Building Code.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee name. Model number, rating and SFM label.
APPROVAL:	Listed as exterior siding for use in the Wildland Urban Interface areas.
NOTES:	Listing formerly: 8140-2024:0005

11/4/14-dg



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/22/2023 Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator Fire Engineering & Investigations Division



LISTING SERVICE

LISTING No.:	8140-2180:0003
CATEGORY:	8140 - EXTERIOR WALL SIDING AND SHEATHING FOR WILDLAND URBAN INTERFACE (W.U.I)
LISTEE:	Plycem USA 396 W. Greens Rd., Suite 300, Houston, TX, 77067 Contact: Herrington, Shawn 844-425-5872 Email: sherrington@elementia.com
DESIGN:	"Weatherboards™" vertical siding, fiber-cement, type "Stucco, Cedar 8"Groove, Cedar (no groove), Smooth, Octagons, 5/16" thick, 4'" width, 8, 9 or 10' length. Refer to the manufacturer's installation instructions and product data sheets.
RATING:	Compliance in accordance with Chapter 7A of the California Building Code.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee name. Model number, rating and SFM label.
APPROVAL:	Listed as exterior siding for use in the Wildland Urban Interface areas.
NOTES:	Listing formerly: 8140-2024:0006

11/4/14-dg



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 07/13/2023 Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator Fire Engineering & Investigations Division